

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmanasa@gmail.com

Payment Receipt

Receipt No. : 33859

Date : 08/05/2026

Invoice No. : INV/2627/00147

Invoice Date : 08/05/2026

Received From : JR MILLENNIUM SCHHOL
NEAR BHAGAT SINGH CHOWK, JOT RAM NAGAR, MANSA

The Sum of Rupees : One Hundred Fifty Six Only.

In Cash

Rs. : 156.00

Disclaimer: -Payment made by cheque/online mode are subject to clearance by bank.

For District Water Testing Laboratory, Mansa
Authorized Signatory

DISTRICT WATER TESTING LABORATORY, MANSA
Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmanasa@gmail.com

To,

JR MILLENNIUM SCHHOL
NEAR BHAGAT SINGH CHOWK, JOT RAM NAGAR, MANSA


No.: DWTL/MNS/2627/00147 Dated : 09/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. JRxx17506 Dated: 08/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 08/05/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Mansa



TC-11306

TEST REPORT

Name & Address of Customer : JR MILLENNIUM SCHHOL NEAR BHAGAT SINGH CHOWK, JOT RAM NAGAR, MANSA		Customer Reference No.	No : JRxx17506 Dated : 08/05/2026
		Sample Submitted by	MR GOSHA SINGH
		Date of Sample Receipt	08/05/2026
		Analysis Starting Date	08/05/2026
		Analysis completion Date	09/05/2026
Discipline :		Group: Water	
ULR No.:	TC113862600000222F	Sample Type :	Water
Test Report No.:	DWTL/MNS/2627/00147	Date of Issue :	09/05/2026
Registration no.:	DWTL/MNS/REG2627/00326	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	JR MILLENNIUM SCHOOL / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Mansa
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.04@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	3	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	NT	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	204	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	78	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	96	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	16.03	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	13.60	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	20.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Mansa

----- End of the Test Report -----